

# APPROVAL FOR CONSTRUCTION

N.H. WATER SUPPLY & POLLUTION CONTROL COMMISSION  
P.O. BOX 95 HAZEN DRIVE, CONCORD, NH 03301

THE PLANS AND SPECIFICATIONS FOR SEWAGE OR WASTE DISPOSAL SYSTEM SUBMITTED FOR:

OWNER:

BRIAN MOORE  
142 GROVE RD.  
RYE, NH 03870

APPROVAL NO. 148979

Lot Numbers: 9  
Subd. Appvl. No.:  
Subd. Name:

COPY OF PLAN & APPROVAL SENT TO:

WILLIAM JENNESS, B.I.  
TOWN OFFICE  
RYE, NH 03870

Type of System: 0000004BR  
000600GPD

Town/City Location: RYE

APPLICANT: PERMIT NO. 000000348

ANNE W. BIALOBRZESKI  
247 LANDING RD.  
HAMPTON, N.H., 03842

Street Location: 142 GROVE RD.

Subsurface waste disposal systems must be operated and maintained in a manner so as to prevent nuisance or health hazard due to system failure. (RSA 149-E:3-b)

It is unlawful to discharge any hazardous chemicals or substances into subsurface waste disposal system. Included are paints, thinners, gasoline and chlorinated hydrocarbon solvents such as TCE, sometimes used to clean failed septic systems and auto parts. (WS 410.05)

ADVISE YOUR CONTRACTOR OF REQUIRED CHANGES  
IN PLANS AS INDICATED BY BELOW CONDITIONS

The system must be constructed in strict accordance with the approved plans and specifications.

The installed system must be left uncovered and cannot be used after construction until it is inspected and finally approved by an authorized agent of the Commission. This is to make certain the system is built according to the approved plans and specifications.

CONTACT THIS OFFICE: 271-3301 OR OUR AUTHORIZED LOCAL AGENT IF ANY WHEN READY FOR INSPECTION!

This system must be installed by an installer holding our permit except an owner may install the system for his domestic exemption.

Approved this date:

06/11/87

By:

GEORGE BERLANDI

N.H. Water Supply & Pollution Control  
Commission Staff

W0017257

(OVER)

APPLICANT'S

## PERC TEST

DATE: 6/13/86

DEPTH OF HOLE: 24"

RATE OF PERC: 4 MIN/IN

DESIGN LOADING: 4 BEDROOMS

AREA REQUIRED: 825 SQ. FT.

PROPOSED SYSTEM: 20x45 FOR  
900 SQ. FT. AREA PROVIDED

REPLACE-  
MENT

PLAN OF PROPOSED  
SEPTIC SYSTEM  
FOR EXISTING HOUSE

LOCUS: 142 GROVE RD  
RYE, NH

OWNER: BRIAN & JOANNE MOORE  
142 GROVE RD  
RYE, NH 03870

APPLICANT: ANNE W. BIALOBRZESKI  
247 LANDING ROAD  
HAMPTON, N.H. 03842  
DESIGNER PERMIT #348

DATE: 3/1/87

APPROVAL:

REVIEWED AND APPROVED  
IN ACCORDANCE WITH THE  
REQUIREMENTS OF THE

NEW HAMPSHIRE  
WATER SUPPLY & POLLUTION  
CONTROL COMMISSION

Signed

Date

148979



69



